

# Consumer Confidence Report 2017

## Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

## Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

## Where does my water come from?

The City of Harrison's water comes from deep groundwater wells. I have included all test results taken for the last five years in this report, so you can see all the tests we take on our source water.

## Source water assessment and its availability

Source water assessment information can be obtained by contacting the Public Works Supervisor, Robert Poole at 208-582-1530.

## Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:

microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

## How can I get involved?

You can be involved by reporting any suspicious activity or illegal dumping to City Hall or call Robert Poole at 208-582-1530.

## Description of Water Treatment Process

Your water is treated by disinfection. Disinfection involves the addition of chlorine or other disinfectant to kill dangerous bacteria and microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

## Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference - try one today and soon it will become second nature.

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit [www.epa.gov/watersense](http://www.epa.gov/watersense) for more information.

## Cross Connection Control Survey

The purpose of this survey is to determine whether a cross-connection may exist at your home or business. A cross connection is an unprotected or improper connection to a public water distribution system that may cause contamination or pollution to enter the system. We are responsible for enforcing cross-connection control regulations and insuring that no contaminants can, under any flow conditions, enter the distribution system. If you have any of the devices listed below please contact us so that we can discuss the issue, and if needed, survey your connection and assist you in isolating it if that is necessary.

- Boiler/ Radiant heater (water heaters not included)
- Underground lawn sprinkler system
- Pool or hot tub (whirlpool tubs not included)
- Additional source(s) of water on the property
- Decorative pond
- Watering trough

## Source Water Protection Tips

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides - they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your

community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.

- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

**Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Harrison is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

**Additional Information for Arsenic**

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

**Water Quality Data Table**

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
<b>Disinfectants &amp; Disinfection By-Products</b>								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl2) (ppm)	4	4	.64	.37	.64	2017	No	Water additive used to control microbes

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Haloacetic Acids (HAA5) (ppb)	NA	60	2.56	NA	NA	2016	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	14.8	NA	NA	2016	No	By-product of drinking water disinfection
<b>Inorganic Contaminants</b>								
Arsenic (ppb)	0	10	3	NA	NA	2013	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	.079	NA	NA	2013	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	.3	NA	NA	2013	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate [measured as Nitrogen] (ppm)	10	10	.09	NA	.09	2017	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
<b>Microbiological Contaminants</b>								
Total Coliform (RTCR)	NA	TT	NA	NA	NA	2017	No	Naturally present in the environment
<b>Radioactive Contaminants</b>								
Alpha emitters (pCi/L)	0	15	2.5	.06	2.5	2016	No	Erosion of natural deposits
Beta/photon emitters (pCi/L)	0	50	5.4	2.4	5.4	2016	No	Decay of natural and man-made deposits. The EPA considers 50 pCi/L to be the level of concern for Beta particles.
Radium (combined 226/228) (pCi/L)	0	5	2.1	1	2.1	2016	No	Erosion of natural deposits
Uranium (ug/L)	0	30	1	NA	10	2016	No	Erosion of natural deposits
Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source	
<b>Inorganic Contaminants</b>								
Copper - action level at consumer taps (ppm)	1.3	1.3	.039	2016	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
<b>Inorganic Contaminants</b>								
Lead - action level at consumer taps (ppb)	0	15	0	2016	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	

**Violations and Exceedances**

## Undetected Contaminants

The following contaminants were monitored for, but not detected, in your water.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Violation	Typical Source
1,1,1-Trichloroethane (ppb)	200	200	ND	No	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (ppb)	3	5	ND	No	Discharge from industrial chemical factories
1,1-Dichloroethylene (ppb)	7	7	ND	No	Discharge from industrial chemical factories
1,2,4-Trichlorobenzene (ppb)	70	70	ND	No	Discharge from textile-finishing factories
1,2-Dichloroethane (ppb)	0	5	ND	No	Discharge from industrial chemical factories
1,2-Dichloropropane (ppb)	0	5	ND	No	Discharge from industrial chemical factories
Antimony (ppb)	6	6	ND	No	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition.
Benzene (ppb)	0	5	ND	No	Discharge from factories; Leaching from gas storage tanks and landfills
Beryllium (ppb)	4	4	ND	No	Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	5	5	ND	No	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints
Carbon Tetrachloride (ppb)	0	5	ND	No	Discharge from chemical plants and other industrial activities
Chlorobenzene (monochlorobenzene) (ppb)	100	100	ND	No	Discharge from chemical and agricultural chemical factories
Chromium (ppb)	100	100	ND	No	Discharge from steel and pulp mills; Erosion of natural deposits
Dichloromethane (ppb)	0	5	ND	No	Discharge from pharmaceutical and chemical factories
Ethylbenzene (ppb)	700	700	ND	No	Discharge from petroleum refineries
Mercury [Inorganic] (ppb)	2	2	ND	No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland
Selenium (ppb)	50	50	ND	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Styrene (ppb)	100	100	ND	No	Discharge from rubber and plastic factories; Leaching from landfills
Tetrachloroethylene (ppb)	0	5	ND	No	Discharge from factories and dry cleaners

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Violation	Typical Source
Thallium (ppb)	.5	2	ND	No	Discharge from electronics, glass, and Leaching from ore-processing sites; drug factories
Toluene (ppm)	1	1	ND	No	Discharge from petroleum factories
Trichloroethylene (ppb)	0	5	ND	No	Discharge from metal degreasing sites and other factories
Vinyl Chloride (ppb)	0	2	ND	No	Leaching from PVC piping; Discharge from plastics factories
Xylenes (ppm)	10	10	ND	No	Discharge from petroleum factories; Discharge from chemical factories
cis-1,2-Dichloroethylene (ppb)	70	70	ND	No	Discharge from industrial chemical factories
o-Dichlorobenzene (ppb)	600	600	ND	No	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	100	100	ND	No	Discharge from industrial chemical factories

**Unit Descriptions**

Term	Definition
ug/L	ug/L : Number of micrograms of substance in one liter of water
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
% positive samples/month	% positive samples/month: Percent of samples taken monthly that were positive
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

**Important Drinking Water Definitions**

Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variations and Exemptions	Variations and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

<b>Important Drinking Water Definitions</b>	
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

**For more information please contact:**

Contact Name: Robert Poole  
Address: PO Box 73  
Harrison, ID 83833  
Phone: 208-689-3212

**Coliform Sampling History**  
PWS Number: ID1280083  
PWS Name: HARRISON CITY OF  
Total Records: 12

Only report coliform results in the CCR if one or more samples tested positive during the 2017 calendar year.

**Required Language.** If your water system's coliform history for the year included one or more samples present for coliform, you must give the major sources of the contaminant. To report this information, go to **Appendix A of the CCR template**, find the contaminant, and copy the information from the *"Major Sources in Drinking Water"* column and place it in your CCR. If the system has exceeded the MCL (maximum contaminant level) value for coliforms, go to **Appendix A of the CCR template**, find the contaminant, and copy the information from the *"Health Effects Language"* column and place it in your CCR.

Contaminant	Date Collected	P=Present A=Absent
COLIFORM (TCR)	12/14/2017	A
COLIFORM (TCR)	11/16/2017	A
COLIFORM (TCR)	10/16/2017	A
COLIFORM (TCR)	09/21/2017	A
COLIFORM (TCR)	08/17/2017	A
COLIFORM (TCR)	07/11/2017	A
COLIFORM (TCR)	06/01/2017	A
COLIFORM (TCR)	05/04/2017	A
COLIFORM (TCR)	04/18/2017	A
COLIFORM (TCR)	03/13/2017	A
COLIFORM (TCR)	02/15/2017	A
COLIFORM (TCR)	01/20/2017	A

Note: Please notify your regional DEQ office if you find discrepancies in your sampling or violation histories. DEQ will correct the errors in the agency's database.



**Lead And Copper Sampling History**  
PWS Number: ID1280083  
PWS Name: HARRISON CITY OF  
Total Records: 4

A public water system is only required to report the most recent 90% percentile detections for lead and copper within the past five years. If a result is listed as zero, it should be assumed the result was actually a non-detect.

Other lead and copper information to be included in the CCR not listed on this page are the number of samples collected from the distribution system, and the highest level of lead or copper that was detected.

**Required Language.** If there are detections for lead and copper to report, the system must give the major sources of the contaminant. If a system reports a detection, the system must give the major sources of the contaminant. To report this information, go to **Appendix A of the CCR template**, find the contaminant, and copy the information from the "*Major Sources in Drinking Water*" column and place it in your CCR. If the system exceeds the MCL (maximum contaminant level) value of a contaminant, the system must show the potential health effects of the contaminant. To report this information, go to **Appendix A of the CCR template**, find the contaminant, and copy the information from the "*Health Effects Language*" column and place it in your CCR.

**Abbreviations used below:**

MG/L (mg/L) = milligrams per liter (mg/L = ppm in Appendix A)

UG/L (µg/L) = micrograms per liter (µg/L = ppb in Appendix A)

Contaminant	# Samples Collected	90th %ile Result	Units	Date Collected	CCR Units
LEAD SUMMARY	5	0.000	MG/L	09/14/2016	0.000
COPPER SUMMARY	5	0.039	MG/L	09/14/2016	0.039
LEAD SUMMARY	5	0.011	MG/L	09/24/2013	11.000
COPPER SUMMARY	5	0.092	MG/L	09/24/2013	0.092

Note: Please notify your regional DEQ office if you find discrepancies in your sampling or violation histories. DEQ will correct the errors in the agency's database.

**DBP Sampling History**  
 PWS Number: ID1280083  
 PWS Name: HARRISON CITY OF  
 Total Records: 18

Sampling history is only listed for systems which are practicing chlorination on a full-time basis.

Public water systems that are required to collect one sample for disinfection byproducts once every year, or every three years, are only required to report the most recent detections for disinfection byproducts. If the most recent sampling was a non-detect for the contaminants, then it is not necessary to report any disinfection byproduct sampling. **Note:** If a contaminant is listed with a "Y" (meaning "Yes") in the "non-detect" column, this means that sampling results showed a "non-detect" - that is to say, the contaminant was not detected.

If a public water system collects more than one sample per year, the system must report the average of Total Trihalomethanes and Haloacetic Acids Group 5 over the 2017 calendar year. The highest level detected, and the range for each contaminant must also be reported.

**Required Language.** If a system reports a detection, the system must give the major sources of the contaminant. To report this information, go to **Appendix A of the CCR template**, find the contaminant, and copy the information from the "Major Sources in Drinking Water" column and place it in your CCR. If the system has exceeded the MCL (maximum contaminant level) value of a contaminant, go to **Appendix A of the CCR template**, find the contaminant, and copy the information from the "Health Effects Language" column and place it in your CCR.

Contaminant	Date Collected	Sampling Location	Non Detect?	Detected Level	Units	CCR Units
TOTAL HALOACETIC ACIDS (HAA5)	09/08/2016	WWTP 2144 PARK	N	2.560	UG/L	2.560
TOTAL HALOACETIC ACIDS (HAA5)	09/20/2013	GENERIC SAMPLING PT	N	1.150	UG/L	1.150
TOTAL HALOACETIC ACIDS (HAA5)	10/25/2010	GENERIC SAMPLING PT	Y	0.000		0.000
TOTAL HALOACETIC ACIDS (HAA5)	10/25/2010	GENERIC SAMPLING PT	Y	0.000		0.000
TOTAL HALOACETIC ACIDS (HAA5)	08/28/2008	GENERIC SAMPLING PT	Y	0.000	MG/L	0.000
TOTAL HALOACETIC ACIDS (HAA5)	08/28/2008	GENERIC SAMPLING PT	Y	0.000	UG/L	0.000
TOTAL HALOACETIC ACIDS (HAA5)	08/28/2008	GENERIC SAMPLING PT	Y	0.000	MG/L	0.000
TOTAL HALOACETIC ACIDS (HAA5)	08/04/2004	GENERIC SAMPLING PT	Y	0.000	MG/L	0.000
TOTAL HALOACETIC ACIDS (HAA5)	08/04/2004	GENERIC SAMPLING PT	Y	0.000		0.000
TTHM	09/08/2016	WWTP 2144 PARK	N	14.800	UG/L	14.800
TTHM	09/20/2013	GENERIC SAMPLING PT	N	15.800	UG/L	15.800
TTHM	10/25/2010	GENERIC SAMPLING PT	N	9.340	UG/L	9.340
TTHM	10/25/2010	GENERIC SAMPLING PT	Y	0.000		0.000
TTHM	08/28/2008	GENERIC SAMPLING PT	N	0.550	UG/L	0.550
TTHM	08/28/2008	GENERIC SAMPLING PT	N	3.180	UG/L	3.180
TTHM	08/28/2008	GENERIC SAMPLING PT	N	4.210	UG/L	4.210
TTHM	08/04/2004	GENERIC SAMPLING PT	Y	0.000	MG/L	0.000
TTHM	08/04/2004	GENERIC SAMPLING PT	N	2.310	UG/L	2.310

Note: Please notify your regional DEQ office if you find discrepancies in your sampling or violation histories. DEQ will correct the errors in the agency's database.